

Certificate of Constancy of Performance

0359-CPR-00183

Issue 2



Appendix to Certificate of Constancy of Performance 0359-CPR-00183

The details and condition of use for the C-Tec ActiV Conventional Range of Fire Detectors, placed on the market by:

Compuionics Limited (Trading as C-Tec)
Challenge Way, Martland Park, Wigan, WN5 0LD

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN54-5:2000 + A1:2002:

Variant	Description
C4403A1R	ActiV Conventional Class A1R rate of rise heat detector
C4403A2	ActiV Conventional Class A2 fixed temperature heat detector
C4403B	ActiV Conventional Class B fixed temperature heat detector
C4414	ActiV Conventional multisensor fire detector <i>Class A2 heat detection</i>

Products compliant with EN54-7:2000 + A1:2002 + A2:2006:

Variant	Description
C4416	ActiV Conventional optical smoke detector <i>Standard optical sensitivity</i>
C4414	ActiV Conventional multisensor fire detector <i>Low optical sensitivity with Class A2 heat enhancement</i>

Bases:

Variant	Description
C4408	ActiV Conventional detector base
C4408D	ActiV Conventional diode detector base

Conditions of use;

Suitable for indoor applications

General Notes:

1. Tested under Intertek project number 100742793.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance

0359-CPR-00183

Issue 2



Appendix to Certificate of Constancy of Performance 0359-CPR-00183 (continued)

<i>Table of performance for EN54-5:2000 + A1:2002</i>			
Harmonised technical specification			
Essential characteristics	Performance	Requirement clauses in this European standard	
		Clauses in EN54-5 2000 + A1:2002	Notes
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2	Clause 6.2 applies to C4403A1R only
Operational reliability	Pass	4.4 to 4.11	
Tolerance of supply voltage	Pass	5.7	
Durability of operational reliability (temperature resistance)	Pass	5.9, 5.10	
Durability of operational reliability (vibration resistance)	Pass	5.14 to 5.17	
Durability of operational reliability (humidity resistance)	Pass	5.11, 5.12	
Durability of operational reliability (corrosion resistance)	Pass	5.13	
Durability of operational reliability (electrical stability)	Pass	5.18	
<i>Note: ActiV detector model number C4414 (Multisensor Fire Detector) also has a declared performance relating to EN54-7:2000 + A1:2002 + A2:2006</i>			

<i>Table of performance for EN54-7:2000 + A1:2002 + A2:2006</i>			
Harmonised technical specification			
Essential characteristics	Performance	Requirement clauses in this European standard	
		Clauses in EN54-7 2000 + A1:2002 + A2:2006	Notes
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	
Operational reliability	Pass	4.2 to 4.7, 4.9 to 4.11	
Tolerance to supply voltage	Pass	5.5	
Durability of operational reliability and response delay; temperature resistance	Pass	5.8, 5.9	
Durability of operational reliability; vibration resistance	Pass	5.13 to 5.16	
Durability of operational reliability; humidity resistance	Pass	5.10, 5.11	
Durability of operational reliability; corrosion resistance	Pass	5.12	
Durability of operational reliability; electrical stability	Pass	5.17	
<i>Note: ActiV detector model number C4414 (Multisensor Fire Detector) also has a declared performance relating to EN54-5:2000 + A1:2002</i>			

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.