

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 0794

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

EP203 conventional three zone "class A" extinguisher control panel for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

**Computationics Limited (Trading as C-Tec)
Challenge Way, Martland Park, Wigan, WN5 0LD**

and produced in the factory

**Computationics Limited (Trading as C-Tec)
Challenge Way, Martland Park, Wigan, WN5 0LD**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Global Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

EN 54 - 2: 1997 + A1: 2006: + A2: 2007 - Fire detection and fire alarm systems - Part 2: Control and indicating equipment

EN 54 - 4: 1997 + A1: 2002 + A2: 2006 - Fire detection and fire alarm systems - Part 4: Power supply equipment

EN 12094 - 1: 2003 - Fixed firefighting systems - Components for gas extinguishing systems -

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 8/8/2008 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Wasantha Hunukumbure
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 11/4/2012
Issue Number: 3
Page: 1 of 3

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0794

The details and conditions of use for the EP203 conventional three zone "class A" extinguisher control panel, placed on the market by Computationics Limited (Trading as C-Tec) Challenge Way, Martland Park, Wigan, WN5 0LD are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Variants:

EP203/DE Conventional three zone "class A" extinguisher control panel German Language Variant

EP203/CON Conventional three zone "class A" extinguisher control panel branded under Context Plus



Wasantha Hunukumbure
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 11/4/2012
Issue Number: 3
Page: 2 of 3

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0794

The details and conditions of use for the EP203 conventional three zone "class A" extinguisher control panel, placed on the market by Computionics Limited (Trading as C-Tec) Challenge Way, Martland Park, Wigan, WN5 0LD are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Incorporating the following units:

SPF0000203	Main extinguisher control
SPF0000212	External relay interface
SPF0003613	Power supply unit
SPF0000214	EP214 terminal

Incorporating as modular units:

EP210S	Remote Status Unit "Surface Mount" optional (See Note 1)
EP211	Economy Status Unit optional (See Note 1)

Certified with the following options with requirements from EN 12094-1:2003

- 4.17 Delay of extinguishing signal
- 4.18 Signal representing the flow of extinguishing agent
- 4.19 Monitoring of the status of components
- 4.20 Emergency hold device
- 4.21 Control of flooding time
- 4.23 Manual only mode
- 4.26 Triggering of equipment outside the system
- 4.27 Emergency abort device
- 4.30 Activation of alarm devices with different signals

Certified with the following options with requirements from EN 54-2:1997

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to the auctioning of outputs fire alarm devices and fire routing equipment
- 7.13 Alarm counter
- 10 Test condition

Note:

- 1) Optional Remote Status Unit part No. EP210S & Economy Status Unit part No. EP211 are not certified as meeting the requirements of the standards specified.
- 2) Meets the requirements of EN12094-3:2003, Class A – i.e. operational temperature range of -5°C to +40°C.

Wasantha Hunukumbure
Certification Manager
For and on behalf of BRE Global Limited



Date of Issue: 11/4/2012
Issue Number: 3
Page: 3 of 3

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.